



NOTES:

1. The canhole through the curb is for overflow if the curb drain tile becomes clogged.
2. Stub house underdrain into ADS Cross and match existing house underdrain diameter.
3. The roof drain pipe shall be encased where it crosses underneath the sidewalk. The concrete encasing shall be 12" deep below finished sidewalk grade and 12" wide.
4. A contraction joint is to be tooled in sidewalk panel directly above roof drain. The pipe shall be encased in 8" of Class "S" concrete beneath the sidewalk.
5. The cap shall be left exposed and no more than 1" above finished grade.

RESIDENTIAL
UNDERDRAIN
JUNCTION BOX
(walk adjacent to curb)

CITY OF GROVE CITY, OHIO

STANDARD
CONSTRUCTION DRAWING

Effective Date
4-15-05

Revision Date
11-15-05

Dwg. No.
C-GC-78B